

Purpose and Background

Upon the next revision of the housing element on or after January 1, 2014, the safety element is required to be reviewed and updated as necessary to address the risk of fire for land classified as state responsibility areas and land classified as very high fire hazard severity zones. (Gov. Code, § 65302, subd. (g)(3).)

The safety element is required to include:

- Fire hazard severity zone maps available from the Department of Forestry and Fire Protection.
- Any historical data on wildfires available from local agencies or a reference to where the data can be found.
- Information about wildfire hazard areas that may be available from the United States Geological Survey.
- The general location and distribution of existing and planned uses of land in very high fire hazard severity zones (VHFHSZs) and in state responsibility areas (SRAs), including structures, roads, utilities, and essential public facilities. The location and distribution of planned uses of land shall not require defensible space compliance measures required by state law or local ordinance to occur on publicly owned lands or open space designations of homeowner associations.
- The local, state, and federal agencies with responsibility for fire protection, including special districts and local offices of emergency services. (Gov. Code, § 65302, subd. (g)(3)(A).)

Based on that information, the safety element shall include goals, policies, and objectives that protect the community from the unreasonable risk of wildfire. (Gov. Code, § 65302, subd. (g)(3)(B).) To carry out those goals, policies, and objectives, feasible implementation measures shall be included in the safety element, which include but are not limited to:

- Avoiding or minimizing the wildfire hazards associated with new uses of land.
- Locating, when feasible, new essential public facilities outside of high fire risk areas, including, but not limited to, hospitals and health care facilities, emergency shelters, emergency command centers, and emergency communications facilities, or identifying construction methods or other methods to minimize damage if these facilities are located in the SRA or VHFHSZ.
- Designing adequate infrastructure if a new development is located in the SRA or VHFHSZ, including safe access for emergency response vehicles, visible street signs, and water supplies for structural fire suppression.
- Working cooperatively with public agencies with responsibility for fire protection. (Gov. Code, § 65302, subd. (g)(3)(C).)

The safety element shall also attach or reference any fire safety plans or other documents adopted by the city or county that fulfill the goals and objectives or contains the information required above. (Gov. Code, § 65302, subd. (g)(3)(D).) This might include Local Hazard Mitigation Plans, Unit Fire Plans, Community Wildfire Protection Plans, or other plans.

There are several reference documents developed by state agencies to assist local jurisdictions in updating their safety elements to include wildfire safety. The Fire Hazard Planning, General Plan Technical Advice Series from the Governor's Office of Planning and Research, referenced in Government Code section 65302, subdivision (g)(3) and available at

1400 Tenth Street
Sacramento, CA 95814
(916) 322-2318

https://www.opr.ca.gov/docs/Final_6.26.15.pdf

provides policy guidance, information resources, and fire hazard planning examples from around California that shall be considered by local jurisdictions when reviewing the safety element of its general plan.

The Board of Forestry and Fire Protection (Board) utilizes this Safety Element Assessment in the Board's review of safety elements under Government Code section 65302.5. At least 90 days prior to the adoption or amendment of their safety element, counties that contain SRAs and cities or counties that

